



Addendum 2026-01.01 to ITB 2026-01 Center Hall Remodel

Question: Please clarify whether CG-02 and DECO MTL-02 refer to the same product. CG-02 is indicated in the details and specifications; however, it is not listed in the finish schedule.

Answer: The CG-02 callout at elevation 2/A401 should be CG-01. At detail 4/A631 it should be DECO MTL-02.

Question: Are pre-bid comparable product substitutions being considered for the specialty ceiling SC-01?

Answer: The Sculptform system was selected to meet the requirement for a metal, non-combustible ceiling. The slats are narrower than those of most comparable metal ceiling systems we have evaluated, and Sculptform offers a wood-look finish that very closely matches the adjacent plastic laminate wood-look panels. While the design team is open to considering substitutions, any alternative product would need to meet all performance requirements and closely match the selected plastic laminate wood appearance.